

Kidde Recalls Fire Extinguishers with Plastic Handles Due to Failure to Discharge and Nozzle Detachment: One Death Reported

Kidde plastic handle fire extinguishers

Name of product:

Kidde fire extinguishers with plastic handles

Hazard:

The fire extinguishers can become clogged or require excessive force to discharge and can fail to activate during a fire emergency. In addition, the nozzle can detach with enough force to pose an impact hazard.

Remedy: Replace

Recall date: November 2, 2017

Recall number: 18-022

Consumer Contact:

Kidde toll-free at 855-271-0773 from 8:30 a.m. to 5 p.m. ET Monday through Friday, 9 a.m. to 3 p.m. ET Saturday and Sunday, or online at www.kidde.com and click on "Product Safety Recall" for more info

What You Need to Do:

KIDDE has requested that you call them at 855-271-0773 or on line @ Kidde 2017 Fire Extinguisher recall for all information & instructions.

You must have your fire extinguisher in front of you to answer any questions, model # and serial # (on the U L sticker) also the manufacturer date ,on the bottom of unit.

Kidde will replace all recalled fire extinguishers with instructions of disposal.

We know a lot of us use these fire extinguishers, at home and on our boats. As we receive additional information, we will pass it along.

This information is courtesy of the ABYA.

